



How to Select the Right Fan

www.amca.org

 **amcainsite**

 **AHR EXPO** *Atlanta*
FEB 6-8

Lisa Cherney

Education Manager, AMCA International
Session Moderator

- Joined AMCA in February 2019
- Responsible for development of AMCA's education programs; staff liaison for the Education & Training Committee
- Projects include webinars, online education modules, presentations at trade shows, AMCA Speakers Network and many other items.



Participation Guidelines

- Please place your cell phone on silent or vibrate.
- There will be Q&A at the end of the session.
- To receive PDH credit for attending:
 - Be sure to have your badge scanned by a room monitor so a complete attendee list can be generated.
 - You must be present for the entire session and complete a post-session online evaluation. Partial credit cannot be given for anyone who arrives late, leaves early or does not complete the evaluation.
 - There will be a QR code for the survey on screen at the end of the presentation, and a link will be emailed to everyone within 2 weeks. The survey must be completed to qualify for today's PDH credit. If you do not want PDH credit, completing the survey is optional, and your feedback is greatly appreciated.

AMCA International has met the standards and requirements of the Registered Continuing Education Program. Credit earned on completion of this program will be reported to RCEP at RCEP.net. A certificate of completion will be issued to each participant. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the RCEP.

*Attendance for the entire presentation
AND a completed evaluation are required
for PDH credit to be issued.*



DISCLAIMER

The information contained in this education session is provided by AMCA International as an educational service and is not intended to serve as professional engineering and/or manufacturing advice. The views and/or opinions expressed in this educational activity are those of the speaker(s) and do not necessarily represent the views of AMCA International. In making this educational activity available AMCA International is not endorsing, sponsoring or recommending a particular company, product or application. Under no circumstances, including negligence, shall AMCA International be liable for any damages arising out of a party's reliance upon or use of the content contained in this education session.

COPYRIGHT MATERIALS

This educational activity is protected by U.S.
and International copyright laws.
Reproduction, distribution, display and use of
the educational activity without written
permission of the presenter is prohibited.

© AMCA International 2023

Jason Meinke

Director of Sales – Commercial Products Twin City Fan

- Over 10 years in the HVAC industry as an engineer and sales leader
- BS in Civil Engineering from University of Minnesota Twin cities
- Focus on new business, channel development and building successful teams
- Has served on several AMCA committees
- Passionate about educating the HVAC community on energy efficiency, reliability and quality



How to Select the Right Fan

Purpose and Learning Objectives

This purpose of this presentation is to review the types of fans and fan construction and address the important fan selection considerations and other factors that should be known in order to ensure the right fan for the right job is guaranteed.

At the end of this presentation, you will be able to:

1. Explain the main reasons why selecting the right fan is critical.
2. Identify the key external factors effecting selection of the proper fan for the job requirements.
3. Describe how energy efficiency, safety and upfront cost all need to be evaluated per project.
4. Outline the questions that need to be asked when making a fan selection.

3 Takeaways

1. We have a choice -
 - Increasing safety requirements
 - Energy efficiency is more important then ever
2. Regulations are here and more are coming
3. Every selection is different and important. Rely on the experts with your questions.



Learning Outcomes



The Case for Change

**Key External Factors
Effecting Selection**



Best Practices

The Case for Change





**Energy
Efficiency**

Safety


Up front Cost



Energy Consumption

Share of total U.S. energy consumption by end-use sectors, 2020

Total = 92.94 quadrillion British thermal units




“Commercial and Industrial buildings account for approximately **51% of total U.S. energy use.**”

- U.S. Energy Information Administration, April 2021



Energy Consumption

The yearly consumption of
Commercial & Industrial fans



2020 US Energy Consumption
27,238,916,784,001 kWh

What we can do - 1% Reduction

Extra households to power
25.6M Households

- Based on average household consumption of 10,649 kWh / year

Savings
\$34.2 Billion

- Based on average US Electricity Rate of 12.55 cents / kWh

Safety – Pandemic

ASHRAE Recommendations for COVID-19


24/7 operation - ASHRAE 62.1 Airflow Recommendations

MERV 13 Filtration

Ultraviolet Germicidal Disinfection

Portable Room Cleaners with HEPA Filter


Increase Outside Air



Safety

NHAPS – Nation, Percentage Time Spent

Total n = 9,196



National Human Activity Pattern Survey

-Funded by EPA (Environmental Protection Agency)

Indoor Air Quality



- Estimated percentage of buildings with complaints related to indoor air quality

Real Consequences

U.S. indirect costs, including missed work and lost productivity.

- **Asthma:** \$5 Billion / Year
 - **Allergic Rhinitis:** \$9.7 Billion / Year
- Asthma & Allergy Foundation of America, 2021*

Environmental Litigation

Dangerous indoor air quality and sick building syndrome are a **growing** area of law for lawyers in the areas of personal injury, real estate, construction, homeowner associations and business.

Return on Investment



Professional Productivity

Average Productivity Savings of Proper Ventilation

\$6,500 /person / year

Average Cost of Proper Ventilation

\$40 /person / year

Return on Investment

16,250%

- U.S. Department of Labor and Harvard University Study, 2017

Student Performance

“54% of public school districts needed to update or replace multiple building systems or features in their schools”

- U.S. Government Accountability Office, June 2020

Proper Ventilation:

Reduced rate of absenteeism

Improves overall health and productivity of Teachers

Improves test scores

External Factors





External Factors

AMCA

OSHA

NFPA

Miami Dade Regulation

OSHPD Regulation



FEI vs. FEG

Wire-to-Air Metric



Software vs. Knowledge



Does software know...

- about energy efficiency requirements?
- what the application is?
- duct design to avoid system effect?
- the latest ASHRAE 62.1 recommendations?
- advise on initial cost vs. cost of ownership?
- safety requirements?
- your project goals and intentions?



External Factors

Your Local Fan
and Ventilation
Representation?



Best Practices



Selection Story


Mike Johnson, the owner of Wood Cutters Direct has reached out to you because they need to add additional dust collection lines to their Manufacturing facility. Through a discussion you have determined that the fan will be on the clean side of the dust collector and that it will require **30,000 CFM at 10 inches** of static pressure when the filters require cleaning.

Some key facts that you have uncovered are:

- Sanding equipment will be used in the system
- There is currently no process set up for fan maintenance at the facility
- When the filters are clean the system requires the fan to overcome 6 inches of static pressure
- The collector currently does not have a mechanism to shut off in the event a filter is ruptured or breaks.
- The fan is outdoors located on a large concrete pad



What Type of Fan Is It?



Centrifugal



Axial



Inline /
Roof Exhaust

Single Width or Double Width?








SWSI



DWDI

What Centrifugal Impeller?

| <u>Airfoil</u> | <u>Backward Inclined</u> | <u>Backward Curved</u> | <u>Forward Curved</u> | <u>Radial Blade</u> | <u>Radial Tip</u> |
|--|---|----------------------------|--------------------------------------|--|---|
| Very High Efficiency | High Efficiency | Higher Efficiency | Medium Efficiency | Low Efficiency | Medium - Low Efficiency |
| Energy savings are of prime importance | Energy savings are important but other factors do not allow for airfoil | Similar effects to airfoil | Low Speed, Noise | Airstream contains heavy particulate or corrosive elements | Airstream contains light particulate and corrosive elements |
| Clean Air, AHU | Clean Air, AHU, Dust Collection, pneumatic conveying | Clean Air | Clean Air, Residential, Low-Cost AHU | Dust Collection | |





Axial Fans

Fan information

| | | | | | |
|---------------------------------|-----------|-----------------------|-------------------|---|-------|
| Size/Model | 28B4/TCVA | Class | III | Outlet Vel (FPM) | 6892 |
| Volumetric Flow (CFM) | 30000 | Speed (RPM) | 4220 | Density (lb/ft ³) | 0.075 |
| SP (in WC) | 1 | Max Speed | 2,456 RPM @ 70 °F | | |
| Blade Angle | 0° | Power (BHP) | 77.16 | | |

Adjusted for



[Back to Type of Fan](#)


Other Fan Types

Fan information

| | | | | | |
|-----------------------|---------|-------------|-------|-------------------------------|-------|
| Size/Model | 365/QSL | Class | I | Outlet Vel (FPM) | 2251 |
| Volumetric Flow (CFM) | 30000 | Speed (RPM) | 1583 | Density (lb/ft ³) | 0.075 |
| SP (in WC) | 10 | Max Speed | 1459 | | |
| | | Power (BHP) | 68.08 | | |

Adjusted for

Standard Plot with System Curve





Fan information

| | | | | | |
|-----------------------|-----------|-------------|-------|-------------------------------|-------|
| Size/Model | 420D/BCRD | Class | N/A | Outlet Vel (FPM) | 2632 |
| Volumetric Flow (CFM) | 30000 | Speed (RPM) | 1389 | Density (lb/ft ³) | 0.075 |
| SP (in WC) | 10 | Max Speed | 615 | | |
| | | Power (BHP) | 64.98 | | |

Adjusted for


Standard Plot with System Curve



Back to Type of Fan

Airfoil

- Is the filter media of the dust collector a bag or a cartridge?
- Does the owner have a fan/collector maintenance schedule?




[Back to Type of Impeller](#)

[Back to Type of Fan](#)


Backward Inclined




Size 300



Size 365



Size 445



[Back to Type of Impeller](#)


[Back to Type of Fan](#)

[Final Selections](#)


Backward Curved




Size 330



Size 445



Size 542



[Back to Type of Impeller](#)

[Back to Type of Fan](#)


[Final Selections](#)

Forward Curved



Size 300

- Too Fast RPM
- Outlet Velocity




Back to Type of ImpellerBack to Type of Fan

Final Selections


Radial Blade



Dirty Filters



Clean Filters



Possible Solution:

- Outlet Damper
- VFD

Outlet Velocity?

Back to Type of Impeller


Back to Type of Fan

Final Selections


Radial Tip



Dirty Filters



Clean Filters



Possible Solution:

- Outlet Damper
- VFD

Back to Type of Impeller

Back to Type of Fan


Final Selections

Options - Selection



Option 1


Backward Inclined Size 365



Cost : 1.0

Option 2


Backward Curved Size 445



Cost : 1.12

Option 3

Radial Tip Size 490




Cost : 2.87

Options - Selection



Option 1

Backward Inclined Size 365




Cost : 1.0

Sound Power Levels

| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|--------|-----|-----|-----|-----|----|----|----|----|-----|
| | 104 | 100 | 104 | 102 | 98 | 95 | 90 | 83 | 104 |

Option 2

Backward Curved Size 445



Cost : 1.12


Sound Power Levels

| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|--------|-----|----|-----|----|----|----|----|----|-----|
| | 100 | 98 | 104 | 96 | 95 | 92 | 87 | 82 | 101 |

www.amca.org

Option 3

Radial Tip Size 490



Cost : 2.87



Direct Drive or Belt Driven?



| | Direct Drive | Belt Driven |
|------|--|---|
| Pros | Low Maintenance <i>Energy Efficiency</i> Safety Smaller Footprint | Low Cost Low Wear and Tear Flexibility |
| Cons | <i>Cost of VFD</i> Difficult Replacement Impeller Weight | High Maintenance Belt Noise Poor Spark Resistance |



Direct Drive or Belt Driven?




Option 1

Backward Inclined Size 365

Fan information

| | | | | | |
|-----------------------|-----------|-------------|-------------------|------------------|-------|
| Size/Model | 365/BC-SW | Class | III | Outlet Vel (FPM) | 3916 |
| Volumetric Flow (CFM) | 30000 | Speed (RPM) | 1510 | Density (lb/ft³) | 0.075 |
| SP (in WC) | 10 | Max Speed | 1,727 RPM @ 70 °F | | |
| | | Power (BHP) | 65.42 | | |

Adjusted for



Direct Drive:
VFD Required

Belt Drive:
VFD Optional

Option 2


Backward Curved Size 445

Fan information

| | | | | | |
|-----------------------|---------|-------------|-------------------|------------------|-------|
| Size/Model | 445/BCS | Class | 14 | Outlet Vel (FPM) | 2634 |
| Volumetric Flow (CFM) | 30000 | Speed (RPM) | 1188 | Density (lb/ft³) | 0.075 |
| SP (in WC) | 10 | Max Speed | 1,202 RPM @ 70 °F | | |
| | | Power (BHP) | 62.89 | | |

Adjusted for

Apply Compressibility



Direct Drive:
VFD Optional

Belt Drive:
VFD Optional

Turn Down vs. Turn Up




Turn Down

1:1 Loss of HP

1800 RPM | 1 HP


1350 RPM | $\frac{3}{4}$ HP

900 RPM | $\frac{1}{2}$ HP



Turn Up

Loss of Torque



Direct Drive or Belt Driven?



Option 1

Backward Incline Size 365

| Fan information | | | |
|-----------------------|-----------|-------------|-------------------|
| Size/Model | 365/BC-SW | Class | III |
| Volumetric Flow (CFM) | 30000 | Speed (RPM) | 1510 |
| SP (in WC) | 10 | Max Speed | 1,727 RPM @ 70 °F |
| | | Power (BHP) | 65.42 |

Adjusted for

Direct Drive:

VFD Required

$(1510 \text{ RPM (Fan Speed)} / 1760 \text{ RPM (Motor Synchronous speed)})$
 $\times 75 \text{ HP (rated HP of Motor)} = 64.34 \text{ HP Remaining}$
 $64.34 \text{ HP (remaining HP)} < 65.42 \text{ BHP (HP required to operate fan)}$

Size Up Required - 100 HP (~+\$3,500)

Belt Drive:

VFD Optional

75 HP

Option 2

Backward Curve Size 445

| Fan information | | | |
|-----------------------|---------|-------------|-------------------|
| Size/Model | 445/BCS | Class | 14 |
| Volumetric Flow (CFM) | 30000 | Speed (RPM) | 1188 |
| SP (in WC) | 10 | Max Speed | 1,202 RPM @ 70 °F |
| | | Power (BHP) | 62.89 |

Adjusted for

Apply Compressibility

Direct Drive:

VFD Optional


75 HP

1188 RPM = Motor Synchronous


Belt Drive:

VFD Optional

75 HP



Direct Drive or Belt Driven?



Xcel Energy Fan Rebates

Must meet FEI rating dependent upon HP

Eligible fans between 1 - 200HP

\$120 - \$9,100 Rebate Potential

Incentivizing use of VFD

To earn rebates, you must be an existing Xcel Energy commercial electric customer in Minnesota who has purchased qualifying equipment from one of our participating distributors.

Qualifying new and retrofit FEI-rated commercial fans and fan systems must meet the following criteria:

- Invoices for qualifying equipment must be dated on or after July 17, 2020.



Direct Drive or Belt Driven?

| | Direct Drive | Belt Drive |
|---------------|--------------|----------------------------|
| VFD | - \$3000 | <i>Optional : - \$3000</i> |
| Drive Package | | - \$850 |
| SGR | - \$1000 | <i>Optional : - \$1000</i> |
| Energy Rebate | + 5,540 | |




| Rebate levels for fans only | | | Rebate levels for fans with an integrated VFD | | |
|-----------------------------|--------------------|---------------|---|--------------------|---------------|
| Fan hp | Minimum FEI rating | Rebate amount | Fan hp | Minimum FEI rating | Rebate amount |
| 1 | 1.12 | \$120 | 1 | 1.12 | \$520 |
| 1.5 | | \$160 | 1.5 | | \$560 |
| 2 | | \$180 | 2 | | \$580 |
| 3 | | \$200 | 3 | | \$600 |
| 5 | | \$220 | 5 | | \$820 |
| 7.5 | | \$240 | 7.5 | | \$990 |
| 10 | | \$260 | 10 | | \$1,260 |
| 15 | 1.22 | \$300 | 15 | 1.22 | \$1,550 |
| 20 | | \$320 | 20 | | \$1,920 |
| 25 | | \$360 | 25 | | \$2,360 |
| 30 | | \$380 | 30 | | \$2,780 |
| 40 | | \$420 | 40 | | \$3,420 |
| 50 | | \$460 | 50 | | \$3,960 |
| 60 | | \$500 | 60 | | \$4,500 |
| 75 | 1.27 | \$540 | 75 | 1.27 | \$5,540 |
| 100 | | \$600 | 100 | | \$6,600 |
| 125 | | \$640 | 125 | | \$7,640 |
| 150 | | \$820 | 150 | | \$7,820 |
| 200 | | \$1,100 | 200 | | \$9,100 |

Direct Drive or Belt Driven?

Fan information


| | | | | | |
|--------------------------|---------|-------------------|-------------------|------------------------|-------|
| Size/Model | 445/BCS | Class | 14 | Outlet Vel (FPM) | 2634 |
| Volumetric Flow (CFM) .. | 30000 | Speed (RPM) | 1188 | Density (lb/ft³) | 0.075 |
| SP (in WC) | 10 | Max Speed | 1,202 RPM @ 70 °F | | |
| | | Power (BHP) | 62.89 | | |

Adjusted for Apply Compressibility



What Motor?

TEFC



75 HP | 1200 RPM | 460V

What Arrangement?



Arrangement 8
Direct Drive
Motor Coupled to Fan Shaft



Arrangement 4VI
Direct Drive - Vertical Inlet Mounted
Impeller Mounted to Motor Shaft



Arrangement 4
Direct Drive
Impeller Mounted to Motor Shaft

75 HP | 1800 RPM | 460V = 1200+ lbs.

What Arrangement?



Arrangement 1
Direct Drive or Belt Driven
Motor Mounted on Floor or Fan Base




Arrangement 3
Belt Driven
Motor Mounted on Floor or Fan Base



Arrangement 9
Belt Driven
Motor Mounted on Pedestal

75 HP | 1800 RPM | 460V = 1200+ lbs.

What Motor Position?




Arrangement 4
Direct Drive
Impeller Mounted to Motor Shaft

Do We Need a Base?



Unitary Base



Isolation Base

Is Dust Dangerous?




2016 – Abbotsford, BC



Is Dust Dangerous?

Recent Explosions Caused by Dust



- May 2017 – Cambria, WI
Didion Milling Facility
- May 2018 – Sioux City, NE
Andersen Farms Grain Elevator
- January 2021 – Brooks, AB
Grain Elevator Fire
- February 2021 – Tuas, Singapore
Stars Engrg – Fire Protection Equipment
- March 2021– Silverton, OR
Crop preparation plant



Is Dust Dangerous?



AMCA Type B
in this case ~25% Add



Type C


AMCA Type C
in this case ~5% Add

Special Material / Coating

What is in the airstream?

Where is the fan located?


What is the air temperature?




What Accessories Do We Need?




Access Door



Belt Guard




Shaft Seal




Shaft and
Bearing Guard

What Accessories Do We Need?



Flex Connectors



Silencer




Outlet Damper



Drain

Congratulations!





Some Other Centrifugal Applications

Air Handling Units

Aeration Systems

Roof Exhaust

Drying / Ovens


Pneumatic Conveying

Pollution Control




Air Handling Units – Supply Fans

Double Wide



Plenum Fan



Plenum
Fan Array



40,000 CFM @ 6.5" WC

Air Handling Units – Fan Compare



| Metric | Double Wide | Single Plenum | 4 Fan Array | 16 Fan Array |
|---------------------|-------------|---------------|-------------|--------------|
| Fan BHP | | | | |
| System BHP | | | | |
| Static Efficiency | | | | |
| Total System FEI | | | | |
| Individual Fan FEI* | | | | |
| System FEP (KW) | | | | |
| System LwA (db) | | | | |
| EQ FLH | | | | |
| KWH | | | | |
| Elec Rate | | | | |
| Operating Cost | | | | |
| Delta | | | | |
| System Cost | | | | |

Air Handling Units – Fan Compare



| Metric | Double Wide | Single Plenum | 4 Fan Array | 16 Fan Array |
|---------------------|-------------|---------------|-------------|--------------|
| Fan BHP | 51.68 | 55.43 | 14.69 | 3.77 |
| System BHP | 53.75 | 55.43 | 58.76 | 60.32 |
| Static Efficiency | 79.3% | 74.0% | 69.8% | 68.0% |
| Total System FEI | 1.27 | 1.27 | 1.25 | 1.22 |
| Individual Fan FEI* | 1.27* | 1.27* | 1.28* | 1.34* |
| System FEP (KW) | 44.04 | 45.41 | 46.13 | 47.35 |
| System LwA (db) | 103 | 96 | 96 | 99 |
| EQ FLH | 6000 | 6000 | 6000 | 6000 |
| KWH | 240,585 | 248,104 | 263,009 | 269,992 |
| Elec Rate | .12 | .12 | .12 | .12 |
| Operating Cost | \$28,870 | \$29,772 | \$31,561 | \$32,399 |
| Delta | Base | \$902 | \$2691 | \$3529 |
| System Cost | 1.15 | 1.0 | 1.58 | 3.23 |

Air Handling Units – Fan Compare



| Metric | Double Wide | Single Plenum | 4 Fan Array | 16 Fan Array |
|---------------------|-------------|---------------|-------------|--------------|
| Fan BHP | 51.68 | 55.43 | 14.69 | 3.77 |
| System BHP | 53.75 | 55.43 | 58.76 | 60.32 |
| Static Efficiency | 79.3% | 74.0% | 69.8% | 68.0% |
| Total System FEI | 1.27 | 1.27 | 1.25 | 1.22 |
| Individual Fan FEI* | 1.27* | 1.27* | 1.28* | 1.34* |
| System FEP (KW) | 44.04 | 45.41 | 46.13 | 47.35 |
| System LwA (db) | 103 | 96 | 96 | 99 |
| EQ FLH | 6000 | 6000 | 6000 | 6000 |
| KWH | 240,585 | 248,104 | 263,009 | 269,992 |
| Elec Rate | .12 | .12 | .12 | .12 |
| Operating Cost | \$28,870 | \$29,772 | \$31,561 | \$32,399 |
| Delta | Base | \$902 | \$2691 | \$3529 |
| System Cost | 1.15 | 1.0 | 1.58 | 3.23 |

Air Handling Units – Fan Compare



| Metric | Double Wide | Single Plenum | 4 Fan Array | 16 Fan Array |
|---------------------|-------------|---------------|-------------|--------------|
| Fan BHP | 51.68 | 55.43 | 14.69 | 3.77 |
| System BHP | 53.75 | 55.43 | 58.76 | 60.32 |
| Static Efficiency | 79.3% | 74.0% | 69.8% | 68.0% |
| Total System FEI | 1.27 | 1.27 | 1.25 | 1.22 |
| Individual Fan FEI* | 1.27* | 1.27* | 1.28* | 1.34* |
| System FEP (KW) | 44.04 | 45.41 | 46.13 | 47.35 |
| System LwA (db) | 103 | 96 | 96 | 99 |
| EQ FLH | 6000 | 6000 | 6000 | 6000 |
| KWH | 240,585 | 248,104 | 263,009 | 269,992 |
| Elec Rate | .12 | .12 | .12 | .12 |
| Operating Cost | \$28,870 | \$29,772 | \$31,561 | \$32,399 |
| Delta | Base | \$902 | \$2691 | \$3529 |
| System Cost | 1.15 | 1.0 | 1.58 | 3.23 |

Air Handling Units – Diffuser Tech

| Metric | Single Plenum | Single Plenum w/ Diffuser |
|-----------------|---------------|------------------------------|
| Fan BHP | 55.43 | 52.90 |
| System BHP | 55.43 | 52.90 |
| S.E. | 74.0% | 77.5% |
| Fan FEI | 1.27 | 1.33 |
| Fan FEP (KW) | 45.41 | 43.34 |
| System FEI | 1.27 | 1.33 |
| System FEP (KW) | 45.41 | 43.34 |
| System LwA (db) | 96 | 96 |

Estimated Sound Pressure

| Distance | 1 | 3 | 5 |
|------------|----|----|----|
| Inlet dBA | 93 | 83 | 79 |
| Outlet dBA | 96 | 86 | 82 |

Sound Power Levels

| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|-----------|----|----|----|----|----|----|----|----|-----|
| Inlet dB | 93 | 98 | 98 | 87 | 83 | 79 | 74 | 71 | 92 |
| Outlet dB | 98 | 99 | 98 | 94 | 91 | 86 | 80 | 74 | 96 |




Estimated Sound Pressure

| Distance | 1 | 3 | 5 |
|------------|----|----|----|
| Inlet dBA | 93 | 83 | 79 |
| Outlet dBA | 96 | 86 | 82 |

Sound Power Levels

| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|-----------|----|----|----|----|----|----|----|----|-----|
| Inlet dB | 93 | 98 | 98 | 88 | 84 | 80 | 74 | 71 | 92 |
| Outlet dB | 98 | 99 | 99 | 94 | 89 | 82 | 75 | 72 | 96 |



Air Handling Units – Diffuser Tech

| Metric | Single Plenum | Single Plenum w/ Diffuser |
|-----------------|---------------|------------------------------|
| Fan BHP | 55.43 | 52.90 |
| System BHP | 55.43 | 52.90 |
| S.E. | 74.0% | 77.5% |
| Fan FEI | 1.27 | 1.33 |
| Fan FEP (KW) | 45.41 | 43.34 |
| System FEI | 1.27 | 1.33 |
| System FEP (KW) | 45.41 | 43.34 |
| System LwA (db) | 96 | 96 |

Estimated Sound Pressure

| Distance | 1 | 3 | 5 |
|------------|----|----|----|
| Inlet dBA | 93 | 83 | 79 |
| Outlet dBA | 96 | 86 | 82 |

Sound Power Levels


| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|-----------|----|----|----|----|----|----|----|----|-----|
| Inlet dB | 93 | 98 | 98 | 87 | 83 | 79 | 74 | 71 | 92 |
| Outlet dB | 98 | 99 | 98 | 94 | 91 | 86 | 80 | 74 | 96 |

Estimated Sound Pressure

| Distance | 1 | 3 | 5 |
|------------|----|----|----|
| Inlet dBA | 93 | 83 | 79 |
| Outlet dBA | 96 | 86 | 82 |

Sound Power Levels

| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|-----------|----|----|----|----|----|----|----|----|-----|
| Inlet dB | 93 | 98 | 98 | 88 | 84 | 80 | 74 | 71 | 92 |
| Outlet dB | 98 | 99 | 99 | 94 | 89 | 82 | 75 | 72 | 96 |



Air Handling Units – Diffuser Tech

| Metric | Single Plenum | Single Plenum w/ Diffuser |
|-----------------|---------------|------------------------------|
| Fan BHP | 55.43 | 52.90 |
| System BHP | 55.43 | 52.90 |
| S.E. | 74.0% | 77.5% |
| Fan FEI | 1.27 | 1.33 |
| Fan FEP (KW) | 45.41 | 43.34 |
| System FEI | 1.27 | 1.33 |
| System FEP (KW) | 45.41 | 43.34 |
| System LwA (db) | 96 | 96 |

Estimated Sound Pressure

| Distance | 1 | 3 | 5 |
|------------|----|----|----|
| Inlet dBA | 93 | 83 | 79 |
| Outlet dBA | 96 | 86 | 82 |

Sound Power Levels


| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|-----------|----|----|----|----|----|----|----|----|-----|
| Inlet dB | 93 | 98 | 98 | 87 | 83 | 79 | 74 | 71 | 92 |
| Outlet dB | 98 | 99 | 98 | 94 | 91 | 86 | 80 | 74 | 96 |

Estimated Sound Pressure

| Distance | 1 | 3 | 5 |
|------------|----|----|----|
| Inlet dBA | 93 | 83 | 79 |
| Outlet dBA | 96 | 86 | 82 |

Sound Power Levels

| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|-----------|----|----|----|----|----|----|----|----|-----|
| Inlet dB | 93 | 98 | 98 | 88 | 84 | 80 | 74 | 71 | 92 |
| Outlet dB | 98 | 99 | 99 | 94 | 89 | 82 | 75 | 72 | 96 |



Air Handling Units – Diffuser Tech

| Metric | Single Plenum | Single Plenum w/ Diffuser |
|-----------------|---------------|------------------------------|
| Fan BHP | 55.43 | 52.90 |
| System BHP | 55.43 | 52.90 |
| S.E. | 74.0% | 77.5% |
| Fan FEI | 1.27 | 1.33 |
| Fan FEP (KW) | 45.41 | 43.34 |
| System FEI | 1.27 | 1.33 |
| System FEP (KW) | 45.41 | 43.34 |
| System LwA (db) | 96 | 96 |

Estimated Sound Pressure

| Distance | 1 | 3 | 5 |
|------------|----|----|----|
| Inlet dBA | 93 | 83 | 79 |
| Outlet dBA | 96 | 86 | 82 |

Sound Power Levels


| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|-----------|----|----|----|----|----|----|----|----|-----|
| Inlet dB | 93 | 98 | 98 | 87 | 83 | 79 | 74 | 71 | 92 |
| Outlet dB | 98 | 99 | 98 | 94 | 91 | 86 | 80 | 74 | 96 |

Estimated Sound Pressure

| Distance | 1 | 3 | 5 |
|------------|----|----|----|
| Inlet dBA | 93 | 83 | 79 |
| Outlet dBA | 96 | 86 | 82 |


Sound Power Levels

| Octave | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | LwA |
|-----------|----|----|----|----|----|----|----|----|-----|
| Inlet dB | 93 | 98 | 98 | 88 | 84 | 80 | 74 | 71 | 92 |
| Outlet dB | 98 | 99 | 99 | 94 | 89 | 82 | 75 | 72 | 96 |




Air Handling Units – Diffuser Tech

| Metric | Single Plenum | Single Plenum w/ Diffuser |
|------------------|---------------|------------------------------|
| Fan BHP | 55.43 | 52.90 |
| System BHP | 55.43 | 52.90 |
| S.E. | 74.0% | 77.5% |
| Fan FEI | 1.27 | 1.33 |
| Fan FEP (KW) | 45.41 | 43.34 |
| System FEI | 1.27 | 1.33 |
| System FEP (KW) | 45.41 | 43.34 |
| System LwA (db) | 96 | 96 |
| EQ FLH | 6000 | 6000 |
| KWH | 248000 | 237000 |
| Elec Rate | .12 | .12 |
| Operating Cost | \$29,760 | \$28440 |
| Delta First Cost | Base | \$1,320 |
| Cost Diffuser | - | ~\$1500 |
| Payback | - | Under 14 Months |



Air Handling Units – Diffuser Tech

| Metric | Single Plenum | Single Plenum w/ Diffuser |
|------------------|---------------|------------------------------|
| Fan BHP | 55.43 | 52.90 |
| System BHP | 55.43 | 52.90 |
| S.E. | 74.0% | 77.5% |
| Fan FEI | 1.27 | 1.33 |
| Fan FEP (KW) | 45.41 | 43.34 |
| System FEI | 1.27 | 1.33 |
| System FEP (KW) | 45.41 | 43.34 |
| System LwA (db) | 96 | 96 |
| EQ FLH | 6000 | 6000 |
| KWH | 248000 | 237000 |
| Elec Rate | .12 | .12 |
| Operating Cost | \$29,760 | \$28440 |
| Delta First Cost | Base | \$1,320 |
| Cost Diffuser | - | ~\$1500 |
| Payback | - | Under 14 Months |



Air Handling Units – Air Velocity

| Metric | 4 Fan Array | 4 Fan Array |
|------------------------------|-------------|-------------|
| Coil / Filter Velocity (FPM) | 500 | 450 |
| CFM | 40000 | 40000 |
| Static | 6.5 | 5 |
| Fan BHP | 14.69 | 11.34 |
| System BHP | 58.76 | 45.36 |
| S.E. | 69.8% | 69.5% |
| Fan FEI | 1.28 | 1.30 |
| Fan FEP (KW) | 11.78 | 9.09 |
| System FEI | 1.25 | 1.27 |
| System FEP (KW) | 46.13 | 35.62 |
| System LwA (db) | 96 | 88 |
| EQ FLH | 6000 | 6000 |
| KWH | 263009 | 203,031 |
| Elec Rate | .12 | .12 |
| Operating Cost | \$31,561 | \$24,363 |
| Delta First Cost | Base | \$7,168 |



Air Handling Units – Air Velocity

| Metric | 4 Fan Array | 4 Fan Array |
|------------------------------|-------------|-------------|
| Coil / Filter Velocity (FPM) | 500 | 450 |
| CFM | 40000 | 40000 |
| Static | 6.5 | 5 |
| Fan BHP | 14.69 | 11.34 |
| System BHP | 58.76 | 45.36 |
| S.E. | 69.8% | 69.5% |
| Fan FEI | 1.28 | 1.30 |
| Fan FEP (KW) | 11.78 | 9.09 |
| System FEI | 1.25 | 1.27 |
| System FEP (KW) | 46.13 | 35.62 |
| System LwA (db) | 96 | 88 |
| EQ FLH | 6000 | 6000 |
| KWH | 263009 | 203,031 |
| Elec Rate | .12 | .12 |
| Operating Cost | \$31,561 | \$24,363 |
| Delta First Cost | Base | \$7,168 |



Air Handling Units – Air Velocity

| Metric | 4 Fan Array | 4 Fan Array |
|------------------------------|-------------|-------------|
| Coil / Filter Velocity (FPM) | 500 | 450 |
| CFM | 40000 | 40000 |
| Static | 6.5 | 5 |
| Fan BHP | 14.69 | 11.34 |
| System BHP | 58.76 | 45.36 |
| S.E. | 69.8% | 69.5% |
| Fan FEI | 1.28 | 1.30 |
| Fan FEP (KW) | 11.78 | 9.09 |
| System FEI | 1.25 | 1.27 |
| System FEP (KW) | 46.13 | 35.62 |
| System LwA (db) | 96 | 88 |
| EQ FLH | 6000 | 6000 |
| KWH | 263009 | 203,031 |
| Elec Rate | .12 | .12 |
| Operating Cost | \$31,561 | \$24,363 |
| Delta First Cost | Base | \$7,168 |



Air Handling Units – Air Velocity

| Metric | 4 Fan Array | 4 Fan Array |
|------------------------------|-------------|-------------|
| Coil / Filter Velocity (FPM) | 500 | 450 |
| CFM | 40000 | 40000 |
| Static | 6.5 | 5 |
| Fan BHP | 14.69 | 11.34 |
| System BHP | 58.76 | 45.36 |
| S.E. | 69.8% | 69.5% |
| Fan FEI | 1.28 | 1.30 |
| Fan FEP (KW) | 11.78 | 9.09 |
| System FEI | 1.25 | 1.27 |
| System FEP (KW) | 46.13 | 35.62 |
| System LwA (db) | 96 | 88 |
| EQ FLH | 6000 | 6000 |
| KWH | 263009 | 203,031 |
| Elec Rate | .12 | .12 |
| Operating Cost | \$31,561 | \$24,363 |
| Delta First Cost | Base | \$7,168 |



Air Handling Units – Supply Fans

01. Making Love Out Of Nothing At All
02. Having You Near Me
03. Lonely Is the Night
04. I Can Wait Forever
05. Goodbye
06. Here I Am
07. Without You
08. All Out Of Love
09. Two Less Lonely People
10. Even The Nights Are Better
11. The Power Of Love
12. Now And Forever
13. Sweet Dream
14. Lost In Love
15. Just As I Am
16. I'll Never Get Enough Of You



3 Takeaways

1. We have a choice -
 - Increasing safety requirements
 - Energy efficiency is more important then ever
2. Regulations are here and more are coming
3. Every selection is different and important. Rely on the experts with your questions.



Q & A

Survey QR Code:



Thank you for your time!

*To receive PDH credit for today's educational session, you **must** complete the online evaluation, either via the QR code or a link, which will be emailed to you 2 weeks of this program.*

*PDH credits and participation certificates will be issued electronically **within 30 days**, once all attendance records are checked and the completed online evaluations are received.*

Attendees will receive an email at the address provided on your 2023 AHR Expo registration, listing the total credit hours awarded and a link to a printable certificate of completion.

If you have any questions, please contact Lisa Cherney, Education Manager, at AMCA International (lcherney@amca.org).



NEXT SESSION @ 1:00PM:

*Update on Fan Efficiency Regulations
finalized for California & in Progress
for U.S. Department of Energy*