

**AMCA** International

# Rain and Hurricane Resistant Louvers



#### **Jim Smardo**

Director Architectural Systems, Ruskin, Kansas City, MO.

jsmardo@ruskin.com

Air System Engineering & Technology (ASET) Conference–US San Antonio, TX • Hyatt Regency San Antonio Riverwalk • March 6 - 7, 2018

Copyright AMCA International • www.amca.org

#### **Professional Development Hours** (PDH) Certificates

The Air Movement and Control Association International (AMCA), has met the standards and requirements of the Registered Continuing Education Providers Program. Credit earned on completion of this program will be reported to the RCEP. A certificate of completion will be issued to each participant. As such, it does not include content that may be deemed or construed to be an approval or endorsement by NCEES or RCEP.



# **Copyright Materials**

This educational activity is protected by U.S. and International copyright laws. Reproduction, distribution, display, and use of the educational activity without written permission of the presenter is prohibited.

© AMCA International



# Learning Objectives

- Transition from traditional louvers to wind driven rain louvers
- Driving specification changes to WDR louvers
- Origin of Code and louver requirements in coastal area's
- Agencies that regulate
- Building Risk categories
- Test Methods

#### **AMCA 500-L**



- 500-L consists of five different testing protocols for testing louvers
  - Pressure Drop
  - Airflow Leakage
  - Water Penetration
  - Wind-Driven Rain
  - Wind-Driven Sand

AMCA 500-L gives you the testing parameters for testing louvers and confirms performance, AMCA 511 was written to give guidance on how to certify the louvers that are tested



#### **AMCA 500-L**

- Upon testing, manufacturers can show that their louver has been part of AMCA's certified ratings program (CRP)
  - Important because not all manufacturers certify product
- Manufacturers can identify which tests have been independently conducted by AMCA with a CRP marking on their submittal page



### **Traditional Louvers**

- Typically sized at 600 to 800 fpm intake velocity
- Drainable blades for intake applications
- Some very high performing traditional models
- How much water is allowed?
  - Adequate drainage
  - Equipment that needs to be kept dry



#### **Rain Penetration**

- Problems
  - Generators
  - Electrical
  - Switchgear
  - Mold Growth
  - Ceilings, Drywall
  - Slick Floors
  - Standing water



### **Traditional Louver Technology**

- Design Characteristics
  - Wide Blade Spacing
  - High Free Area
  - Low Cost
  - Low Pressure Drop
  - Not Effective In Storms



#### Wind Driven Rain Louver Technology

amco

AIR

- Design Characteristics
  - Close Blade Spacing
  - Lower Free Area
  - Greater Velocities
  - Higher Pressure Drop
  - Effective water rejection in storm conditions

# **Still Air Test**

- Test Conditions
  - 4" per hour rain light vertical rain
  - 1250 fpm max free area velocity
  - Approx. 14 mph
  - Tested for beginning point of water penetration based on free area velocity
  - 48" x 48" sample size
  - No screen



#### **Still Air Test**



Still Air

#### **Beginning Point of Water** penetration-.01 oz. of water per sq/ft. at X FPM F.A. Vel.



### **AMCA 500-L Still Air Test Louvers**

- Defines the beginning point of water penetration by intake air velocity where water begins to penetrate the louver
  - Not meant to give water penetration under service conditions (wind-driven rain)
     WATER PENETRATION
     THE SERVICE AND (2019)





#### Wind Driven Rain Technology



AMCA ASET-US Conference, San Antonio, TX

# AMCA 500-L Wind-Driven Rain Test for Louvers

- The chamber behind the louver is fully pressurized with an exhaust fan trying to draw water through the louver's blades during the testing procedure (30 minute testing period)
  - Test values are noted at regular intervals and are not more than 10 minutes apart
  - The test procedure is completed when a minimum of 4 consecutive readings within the steady state of tolerance has been noted



#### **WDR Test**



AMCA ASET-US Conference, San Antonio, TX

#### **AMCA500-L Wind Driven Rain Test**

WIND-DRIVEN RAIN PERFORMANCE – AMCA 500-L WIND-DRIVEN RAIN TEST	
Test size is 1m x 1m (39" x 39") core area, 1.05m x 1.08m (411/4" x 425/16") nominal. Free Area of test louver is 4.86 ft <sup>2</sup> (.45m <sup>2</sup> ).	

Wind Velocity mph (kph)	Rain Fall Rate In./hr. (mm/hr.)	Core Velocity <sub>1</sub> fpm (m/s)	Airflow cfm (m⁰/min)	Free Area Velocity <sub>2</sub> fpm (m/sec.)	Effectiveness Ratio	Class <sub>3,4</sub>	Discharge Loss Class ₅ Intake
29 (46.4)	3 (76)	970 (5)	10,444 (295)	2,149 (10.9)	99.9%	A	2
50 (80.5)	8 (203)	982 (5)	10,570 (298)	2,175 (11.0)	99.8%	A	2

NOTES

1. Core area is the open area of the louver face (face area less louver frames).

Core Velocity is the airflow velocity through the Core Area of the louver (1m x 1m). 5 m/s is the maximum core velocity utilized in this test.

2. Free Area of test size is calculated per AMCA standard 500-L.

3. Wind Driven Rain Penetration Classes:

- Class Effectiveness
- A 1 to .99
- B 0.989 to 0.95
- C 0.949 to 0.80
- D Below 0.8
- 4. The EME6625 provides class A performance at all velocities up to and including 5 m/s core velocity.
- Discharge Loss Coefficient is calculated by dividing a louvers' actual airflow rate vs. a theoretical airflow for the opening. It provides an indication of the louvers' airflow characteristics.
  - Class Discharge Loss Coefficient
  - 1 0.4 and above
  - 2 0.3 to 0.399
  - 3 0.2 to 0.299
  - 4 0.199 and below

(The higher the coefficient, the less resistance to airflow.)

6. The AMCA Wind Driven Rain Test is performed in a laboratory environment and incorporates controlled wind, water and system airflow effects. In actual field installations, storms may create conditions not considered by the AMCA test. Penthouse and similar applications where wind can pass through multiple louvers in an enclosure is another condition that is not simulated by AMCA tests. These applications can create elevated water penetration rates through any louver. Because of these uncontrolled situations it is recommended that provisions to manage water penetration through louvers be included in the building design.



Ruskin Company certifies that the Louver shown herein is licensed to bear the AMCA Seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with the requirements of the AMCA Certified Ratings Program. The AMCA Certified Ratings Seal applies to air performance ratings and wind driven rain ratings only.

#### Class A – 99% to 100% effective Class B – 95% to 98.9% effective Class C – 80% to 94.9% effective Class D – Anything below 80% effective



AMCA ASET-US Conference, San Antonio, TX

#### **Still Air VS WDR**



#### AMCA Wind Driven Rain test

<u>Based on</u> Wind Driven Rain test- 3" per hour at 29 mph wind velocity, wind tunnel pulling 1300 FPM

29 liters = Approximately 7 gallons

# Sizing Tips

- Free area not necessarily the most important characteristic
- Pressure drop generally becomes the limiting factor
  - Low free area can be offset by low pressure drop
  - Still area louvers require a (15% to 25%) safety factor WDR louvers do not
  - At 10,000 CFM a 6" still air louver with 860 fpm fav requires a 48" x 60" louver – A 6" vertical WDR with 2019 fpm fav requires a 42" x 42" louver
  - A difference if 7.75 sq. ft.. face area.

# Sizing Louvers – 48" Sq.

#### **6" Horizontal Still Air**

- Free Area: 9.08 ft<sup>2</sup> 57%
- F.A. Vel.: 870 fpm
- Volume: 7,900 cfm
- .13" Δp
- No W.D. Rain Resistance



#### **5" Horizontal WDR**

- Free Area: 6.99 ft<sup>2</sup> 44%
- F.A. Vel.: 1327 fpmVolume: 9,276 cfm
- .25" ∆p
- 99.7% Rain Resistance (29 mph/3" hr)
- 17% More Volume!

# Sizing Louvers – 48" Sq.

#### **6" Horizontal Still Air**

- Free Area: 9.08 ft<sup>2</sup> 57%
- F.A. Vel.: 870 fpm
- Volume: 7,900 cfm
- .13" Δp
- No WDR resistance
- Best Still Air 65% @ 3" 29mph

#### **6" Vertical WDR**

- Free Area: 6.80 ft<sup>2</sup> 43%
- F.A. Vel.: 2175 fpm
- Volume: 14,790 cfm
- .35" Δp
- 99.8% Rain Resistance (50 mph/8" hr)
- 87% More Volume!



#### **Hurricane Louvers**



#### Organizations associated with Florida & Coastal codes for louvers



Miami-Dade http://www.miamidade.gov/building



ICC http://www.iccsafe.org/



AMCA https://www.amca.org/



Florida Building Code https://floridabuilding.org

# What Started the Code Requirements in Florida

- Hurricane Andrew made land fall in South Florida in August of 1992
- Only one of three hurricanes to hit land while still a Category 5
   Hurricane
- 165 mph winds sustained/over 200 mph wind gusts





#### The Aftermath of Andrew

• \$26.5 Billion in damage - In Todays Dollars \$50 billion



AMCA ASET-US Conference, San Antonio, TX

#### **Hurricane Louvers**

- Understanding the International Building Code and International Mechanical Code Requirements for louvers in the Hurricane-Prone and Wind-Borne Debris Region(s)
- Explanation of applicable louver test procedures for louvers in the Hurricane-Prone and Wind-Borne Debris Region(s)
  - AMCA 540 and AMCA 550

# International Code Council (ICC)

- Standards for construction
  - No testing protocols
  - Does reference AMCA 540/550 for coastal regions along the Atlantic and gulf coast



## IBC 2012/2015 Building Code Language

IBC 2012/2015 Building Code

**Chapter 2: Definitions** 

- Wind-Borne Debris Region. Areas within hurricane-prone regions located:
  - Within 1 mile (1.61 km) of the coastal mean high water line where the ultimate design wind speed, V ult, is 130 mph (58 m/s) or greater; or
- In areas where the ultimate design wind speed is 140 mph (63.6 m/s) or greater.

### IBC 2012/2015 Building Code Language

IBC 2012/2015 Building Code Chapter 16: Structural Design

- 1609.1.2.1 Louvers. (as it pertains to the Wind-Borne Debris Region)
- "Louvers protecting intake and exhaust ventilation ducts not assumed to be open that are located within 30 feet (9144mm) of grade shall meet the requirements of AMCA 540."

#### 2017 Florida – 6th Edition

- Plumbing
- Residential
- Energy Conservation
- Building
- Mechanical
- Test Protocols
- Accessibility
- Existing Building
- Fuel Gas
- Went into effect Dec. 31st 2017



#### **2017 Florida 6th Edition**







Δ

#### **ANSI/AMCA 540-Test Method of Louvers Impacted by Wind Borne Debris**

- Test procedure measures a products capacity to withstand impact from wind borne debris in hurricane wind velocities
  - Test Missile: 9 lb 2 x 4
  - Distance: 12-feet (9 ft.. long missile)
  - Impact Velocity:
    - 3 units tested
    - Shortest blade span
    - Longest unsupported span
    - Mullion location



# **AMCA Testing Standards - 540**

#### • AMCA 540

- Pass/Fail Criteria
  - No penetration of the blade material by the excepting fragments
  - Fragments produced by the missile shall not exceed five per cent of the missile's weight
  - Louver must remain attached to adjacent parts or components







# **AMCA Testing Standards - 540**

#### • AMCA 540

Figure 1

- Minimum of three specimens impacted
  - Requires the minimum and maximum sections to be tested
  - Can be one single-section and one multi-section



#### IBC 2012/2015

• Building Risk category I & II



AMCA ASET-US Conference, San Antonio, TX

### IBC 2012/2015

Building Risk category I & II



 Wind speeds correspond to approximately a 15% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00333, MRI = 300 years).

170

#### **Risk Categories of Buildings and Other Structures**

#### Category I

- Buildings and structures that represent a low hazard to human life in the event of failure
- Wind velocity (3-second gusts) used in calculations are 165 mph (Miami-Dade) and 156 mph (Broward)
- Includes but not limited to:
  - Agricultural facilities
  - Certain temporary facilities
  - Minor storage facilities
  - Screen enclosures



#### **Risk Categories of Buildings & Other Structures**

#### Category II

- Buildings and other structures except those listed in Risk Categories I, III, and IV
- Wind velocity (3-second gusts used in calculations are 175 mph (Miami-Dade) and 170 (Broward)
- Examples:
  - Typical business with occupancy load less than 300
  - Non-essential facilities



#### IBC 2012/2015

Building Risk category III & IV



120

#### IBC 2012/2015

Building Risk category III & IV



#### Notes:

150

130

140

150

1. Values are ultimate design 3-second gust wind speeds in miles per hour (m/s) at 33 ft (10m) above ground for Exposure C category.

115

120

2. Linear interpolation between contours is permitted.

3. Islands and coastal areas outside the last contour shall use the last wind speed contour of the coastal area.

 Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.

5. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 years).



#### **Risk Categories of Buildings & Other Structures**

#### Category III

- Buildings and other structures that represent a hazard to human life in the event of failure
- Wind velocity (3-second gusts) used in calculations are 186 mph (Miami-Dade) and 180 mph (Broward)
  - Examples include but are not limited to:
    - Buildings or structures whose primary occupancy is public assembly with an occupant load greater than 300
    - Buildings or structures containing elementary schools, secondary schools or day care facilities with an occupant load greater than 250
    - Adult education facilities such as colleges and universities with an occupant load of greater than 500
    - Power-generating stations, water treatment facilities for potable water, waste water treatment facilities, and other public utility facilities not covered by Category IV
    - Occupancies with occupant loads of 50 or more resident patients but not having surgery or emergency treatment facilities



#### **Risk Categories of Buildings & Other Structures**

#### **Category IV**

 Buildings and other structures designated as essential facilities



- Wind velocity (3-second gusts) used in calculations are 186 mph (Miami-Dade) and 180 mph (Broward)
  - Examples include but are not limited to:
    - Fire, rescue, ambulance and police stations
    - Emergency treatment facilities
    - Designated earthquake, hurricane or other emergency shelters
    - Power-generating stations and other public utility facilities required as emergency backup facilities for Risk Category IV structures
    - Aviation control towers, air traffic control centers, and emergency aircraft hangers
    - Buildings critical for national defense
    - Water storage facilities and pump structures required to maintain water pressure for fire suppression

### **Know the Difference**

#### • Missile Level D

- 9 lb 2 x 4 at 34 MPH
- Required for "Basic Protection" where louvers are required to be impact qualified per FBC 2014

#### • Missile Level E

- 9 lb 2 x 4 at 55 MPH
- Required for "Enhanced Protection" where louvers are required to be impact qualified per FBC 2014 for Critical or Essential Facilities







#### Hurricane zone

- Florida 2010 declared entire state of Florida hurricane zone
- Must have AMCA 550





AMCA ASET-US Conference, San Antonio, TX

## IBC 2012/2015 Building Code Language

2012/2015 International Mechanical Code

**Chapter 2: Definitions** 

- Hurricane-Prone Regions. Areas vulnerable to hurricanes defined as:
  - The U.S. Atlantic Ocean and Gulf of Mexico coasts where the ultimate design wind speed, V ult, for Risk Category II buildings is greater than 115 mph (51.4 m/s); and
  - Hawaii, Puerto Rico, Guam, Virgin Islands and American Samoa.

## IMC 2012/2015 Building Code Language

2012/2015 International Mechanical Code

**Chapter 4: Ventilation** 

- 401.5 Intake opening protection.
- "Louvers that protect air intake openings in structures located in the hurricane-prone regions, as defined in the International Building Code, shall comply with AMCA 550."

# **AMCA Listing Standards - 550**

#### • AMCA 550

- Water shall be supplied to the wind stream using a sprinkle pipe system simulating a uniform 8.8 inches/hour (223.5 mm/hour) over the test specimen
- Eight intervals of testing
  - Five to fifteen minutes
  - Wind Speeds from 0 mph to 110 mph
- Pass/Fail is determined by whether or not the louver exhibits water infiltration in excess of 1% of the total water sprayed



#### ANSI/AMCA 550-Test Method for High Velocity Wind Driven Rain Resistant Louvers



AMCA ASET-US Conference, San Antonio, TX

- Louver test specimen size must exhibit a 1m x 1m "core" area
- No more than 1% of the total sprayed water volume may penetrate the louver to pass

Interval	Wind Speed	Duration	Water Spray
1	35 mph	15 min	On
2	0 mph	5 min	Off
3	70 mph	15 min	On
4	0 mph	5 min	Off
5	90 mph	15 min	On
6	0 mph	5 min	Off
7	110 mph	5 min	On
8	0 mph	5 min	Off

#### Miami-Dade County Product Approval

- Miami-Dade County Department of Regulatory and Economic Resources governs the safety and vitality of local businesses and shopping areas in Broward and Miami Dade counties
  - Responsible for enforcing the requirements necessary for commercial construction in South Florida
    - Products that are approved for Miami-Dade construction carry an NOA (Notice of Acceptance)



AMCA ASET-US Conference, San Antonio, TX

#### **Different with some Similarities**



- Required for projects that are in Dade or Broward county in Florida
- Miami-Dade Notice of Acceptance (NOA)
- Requires TAS 201, TAS 202, TAS 203
- Currently requires AMCA 540 and AMCA 550 which is recognized in coastal states



- Required throughout the state of Florida
- Created test protocols for TAS 201, TAS 202, and TAS 203
- Currently 6th edition 2017
- 2017 FBC requires AMCA 540 and AMCA 550 which is recognized in coastal states

- TAS 201 Missile Impact Test Referenced from FBC (ASTM Standards)
  - Southern pine 2 x 4 between seven and nine feet
  - Weight must be between 9 and 9.5 pounds
  - Missile impacts the surface at 50 feet per second
  - Three test specimens (Two can be multi-section louvers)
  - Each test specimen must be impacted twice
  - Requires that TAS 203 is run after TAS 201 testing is completed
  - Pass/Fail test

#### **AMCA 540 vs TAS 201**

- Distance of cannon to sample
- Smallest louver size offered
- While initial velocity is same, distance traveled means more severe impact

Test Standard	AMCA 540	TAS 201
Missile Material	2 x 4 timber	2 x 4 timber
Missile Weight	9 lb (4.1 kg)	9 lb (4.1 kg)
Missile Velocity	50 fps (15.2 m/s)*	50 fps (15.2 m/s)
Distance from cannon to sample	1.5 x length of missile (ft) 10.5 feet in this example	9 feet + length of missile 16 feet in this example
Minimum Sample Size	Smallest section louver to be offered	N/A
Maximum Sample Size	Maximum unsupported blade span by maximum height	Maximum width offered x maximum height offered
Mullion Impact Required on Maximum Height Multi-section Assembly	Yes	Yes

- TAS201-Distance from cannon to test sample- 17 ft...@ 34 MPH
- AMCA 540 level D- Distance from cannon to test sample-12 ft...@ 34 MPH
- AMCA 540 level E Distance from cannon to test sample-12 ft...@ 55 MPH

- TAS 202 Static Pressure Test Referenced form FBC (ASTM Standards)
- The unit is tested in both directions up to 1.5 times the rated load
  - For example, a louver rated for 150 psf would be tested in TAS 202 at 225 psf
- Pass/Fail test



- TAS 203 Cyclic Wind Pressure Test
  - Follows TAS 201 testing
  - Consists of supplying air to and exhausting air from the chamber in accordance with a specific test loading program at the rate required to maintain the test pressure differential across the specimen and observing the distress or failure of the specimen
  - Load must be applied in both positive and negative directions 150 PSF LOUVER TESTING
  - -40% DESIGN LOAD = 60 PSF 600 cycles
  - -60% DESIGN LOAD = 90 PSF -70 cycles
  - 130% DESIGN LOAD = 195 PSF
  - Pass/Fail test

March 6-7, 2018



- TAS 100A Wind-Driven Rain
  - Required for louvers within 33 feet of grade where the room behind the louver is NOT designed to drain water penetrating into the room or the room will not house non-water resistant or weather proof equipment
  - Simulates an external 35, 70, 90, and 110 miles per hour wind speed with a simulated rainfall rate of 8.8 inches per hour
  - During the 35 and 70 miles per hour wind simulation, no water penetration is allowable
  - During the 90 and 110 miles per hour wind simulations, an amount of water not greater than 0.05% of the overall sprayed water volume is allowed beyond the louver and damper assembly
  - Testing protocol is same as AMCA 550
  - Very few louvers pass by themselves (Vertical in design)
  - AMCA 550 is accepted by MD and allows 1% vs .5% TAS 100A

# How do I identify FBC louvers?

#### Ratings

Free Area: [48" × 48" (1222 × 1222) unit]: 7.4 ft<sup>2</sup> (0.69 m<sup>2</sup>) 46.3% Performance @ Beginning Point of Water Penetration Free Area Velocity: Above 1250 fpm (6.35 m/s) Air Volume Delivered: Above 9250 cfm (4.37 m∛s) Pressure Loss: 0.22 in.wq. (65 Pa) Velocity @ 0.15 in.wg. Pressure Loss: 1030 fpm (6.24 m/s) AMCA 540 (impact resistance) and AMCA 550 (high velocity winddriven rain) listed. Miami Dade County: NOA No. 15-0428.01 (Expires 10/23/2018) Approved to FBC TAS202-94, TAS201-94 Florida Building Code Approval (2014-FBC): No. FL17876 Design Load: 150 psr

Florida Product Approval No: FL12941.1 Miami-Dade NOA No.: 14-0624.16, EXP. 8/5/19 TDI Approval No.: LVR-06 Maximum Wind-load: 110 PSF

MIAMI-DADE APPROVED

FLORIDA PRODUCT APPROVAL # FL3268.1

MIAMI-DADE COUNTY, FLORIDA NOTICE OF ACCEPTANCE NUMBER: 12-0628.06 (1/28/17)

MIAMI-DADE APPROVED

MIAMI-DADE COUNTY, FLORIDA NOTICE OF ACCEPTANCE #: 15-0420.04 (EXPIRES 01-17-16) FLORIDA BUILDING CODE PRODUCT APPROVAL #: FL3284-R4

#### **Searching for approved FBC** louvers



BCIS Home Log In User Registration Hot Topics Submit Surcharge Stats & Facts Publications FBC Staff BCIS Site Map Links Search

Product Approval

Product Approval Menu > Product or Application Search

USER: Public User

You can search for products by FL number or by any search criteria. Each criteria selected narrows the scope of your search so be sure to start broad by selecting only one or two criteria. If you have the FL#, enter the FL# and the appropriate code version of the application and click search. If you are seeking the FL#(State Product Approval Number), select the product manufacturer and the code version and click search. Please note that the default code version is 2010 Florida Building Code which became effective March 15, 2012. Some searches may require you to select more than one criteria to limit large system searches.

Search Criteria			
Application			
Conorate Output			
Generate Output	HTML O Crystal Report		
Code Version	2014 🗸		
FL #	FL		
Application Type	(Select All)		
Product Manufacturer	(Select All)		
Category	(Select All)		
Subcategory	(Select All)		
Application Status	(Select All)		
Compliance Method	(Select All)		
Quality Assurance Entity Contract Expired			
Product			
Product Model, Number or Name			
Product Description			
Approved for use in HVHZ	(Select All) 🗸		
Approved for use outside HVHZ	(Select All) 🗸		
Impact Resistant	(Select All) 🗸		
Design Pressure	+ / □ N/A		
Other			

Source: https://floridabuilding.org/pr/pr\_app\_srch.aspx

# How do I identify Miami-Dade NOA louvers?

#### Ratings

Free Area: [48" × 48" (1222 × 1222) unit]: 7.4 ft<sup>2</sup> (0.69 m<sup>2</sup>) 46.3%

Performance @ Beginning Point of Water Penetration

 Free Area Velocity:
 Above 1250 fpm (6.35 m/s)

 Air Volume Delivered:
 Above 9250 cfm (4.37 m³/s)

 Pressure Loss:
 0.22 in.wg. (55 Pa)

Velocity @ 0.15 in.wg. Pressure Loss: 1030 fpm (6.24 m/s)

AMCA 540 (impact resistance) and AMCA 550 (high velocity winddriven rain) listed.

Miami Dade County: NOA No. 15-0428.01 (Expires 10/23/2018) Approved to FBC TAS202-94, TAS201-94 and TAS203-94.

Florida Building Code Approval (2014-FBC): No. FL17876 Design Load: 150 psf Florida Product Approval No: FL12941.1 Miami-Dade NOA No.: 14-0624.16, EXP. 8/5/19 TDI Approval No.: LVR-06

Maximum Wind-load: 110 PSF

MIAMI-DADE APPROVED

FLORIDA PRODUCT APPROVAL # FL3268.1

MIAMI-DADE COUNTY, FLORIDA NOTICE OF ACCEPTANCE NUMBER: 12-0628.06 (1/28/17)

MIAMI-DADE APPROVED

MIAMI-DADE COUNTY, FLORIDA NOTICE OF ACCEPTANCE #: 15-0420.04 (EXPIRES 01-17-16) FLORIDA BUILDING CODE PRODUCT APPROVAL #: FL3284-R4

#### **Searching for approved Miami-Dade louvers** miamidade.gov Departments Government Employees Visitors Calendar Transparency Call 3-1-1 Website Search Welcome to the new RER website. Our goal is to provide better

ATOR content and make it easier to access. Please help us succeed by providing feedback about the new site. We will be listening and working hard to keep improving. Home Buildina Business Environment Licenses Permits Planning Zoning Building Last Visited » Approval Process » Product Approval Forms » Building » Product Control Search Product Control Search You can search our database for products, certificates and listings that have been approved for use on buildings in both Miami-Dade County and throughout the MIAMI-DADE COUNTY country Basic Search To find a particular item, enter the File Number Search by File Go (i.e.: 01-0712.04). Advanced Search Choose values for one. File Classification Unknown / Unselected ~ Go several or all search Applicant All (Select All) ~ Reset parameters. Each value that you choose Category ~ All (Select All) narrows the scope of your search. × Subcategory All (Select All) × Material (Select All) All Impact Rating All (Select All)  $\sim$ 

Search

Source: http://www.miamidade.gov/building/pc-search\_app.asp

# How do I identify louvers that are AMCA 540/550 listed?



Cat I, II, and III buildings and structures



AMCA airflow performance certification.



HIGH VELOCITY RAIN RESISTANT WITH BLADES FULLY CLOSED

See www.AMCA.ora for all certified or listed products

IMPACT RESISTANT

LOUVER

Enhanced Protection Level E

See www.AMCA.ora for all certified or listed products

Cat I, II, III, and IV buildings and structures

- Not a requirement for Miami-Dade for FBC 2014
- Listing adds credibility to the testing conducted on the louver

#### Searching for AMCA 540/550 louvers



#### Source: http://www.amca.org/certified-listed/listedproducts.php

# Summary

- Traditional louver's offer high FA and low pressure drop but do not provide WDR performance
- WDR louvers stop water penetration and allow greater FA velocities
- WDR allows for smaller footprint of louver sizes
- WRD louvers do not require a safety factor
- ICC is a guideline for building codes, but does not mandate testing
- Agencies such as AMCA, FBC, and Miami-Dade all participate in certifying louvers
  - Miami Dade
    - NOA for acceptable louver products
      - Based on calculations supplied and testing data
  - AMCA
    - 540 (basic and enhanced impact test)
    - 550 High velocity wind driven rain test
  - FBC 2017
    - AMCA 540
    - AMCA 550

# Questions?

#### Jim Smardo Director Architectural Systems Ruskin Company/JCI jsmardo@ruskin.com